



The City of
MIDWEST CITY
 COMMUNITY DEVELOPMENT DEPARTMENT

**DRIVEWAY ENTRANCE FOR MIDWEST CITY
 CODE SECTION 37, TABLE 4**

Use	Commercial		Industrial			Residential
	Arterial	Non-Arterial	Arterial	Non-Arterial	Arterial	Non-Arterial
Distance from Intersecting Non-Arterial Street or Property Line[^]	35 feet*	25 feet*	35 feet*	25 feet*	35 feet	0 feet
Minimum Width	24 feet	24 feet	24 feet	24 feet	18 feet	12 feet
Maximum Width	30 feet	24 feet	36 feet	30 feet	24 feet	24 feet
Max Radius	25 feet	25 feet	25 feet	25 feet	20 feet	15 feet
Min Radius	15 feet	10 feet	15 feet	15 feet	10 feet	0 feet
Thickness of 3,500 PSI Concrete	6 inches	6 inches	8 inches	8 inches	6 inches	6 inches
Subgrade	4 inches	4 inches	6 inches	6 inches	4 inches	4 inches
Provisions for Sidewalk Crossing if none exist	Yes	Yes	Yes	Yes	Yes	No
Max Grade	10.0%					
Minimum Grade	0.5%					
For asphalt street, saw cut width of curb and gutter						
For concrete street, saw cut width of 2 inches						
Drive elevation shall be such that drainage water will not enter drive						
*A drive can be adjacent to property line if a shared use driveway with the adjoining property						
[^] Drives adjacent to Arterials will be subject to variables such as signal, traffic flow, and property frontage.						

Variations for driveways to high volume traffic generators may be approved by the City Engineer. Driveways for service stations may be designed using “Standard Design for Driveway Entrances,” Oklahoma Highway Department, subject to approval of the City Engineer.